

MDDDB Ltd
7 Vanzell Road
Easebourne
Midhurst
GU29 9BA

Date: 12th October 2020

Please ask for: Maria Tomalova
Tel: 01903 737510

Your Ref:

Our Ref: BN/92/20/DOC

Dear Mr Davies,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref BN/23/15/PL relating to Condition Nos 5 - surface water drainage, 6 - discharge of flows and 7 - future access & maintenance of any watercourse or culvert.

Windermere Lake Lane Barnham PO22 0AD

Notification regarding the above application:

Condition Number 5

Development shall not commence until details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and maintained in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

The details submitted in respect of the proposed surface water drainage scheme, namely the following items have been appraised by the Councils Drainage Engineers, are considered to be acceptable and

satisfy the requirements of the condition.

Dwg 535/01 Rev F dated 14/08/20; and
Dwg 535/02 Rev A dated 07/10/20

The condition is therefore discharged on the understanding that the surface water drainage scheme will be implemented in accordance with the approved scheme and permanently retained in good working order thereafter.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning