

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 21 February 2020 08:54
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: BN/93/19/PL - Angels Nursery, Yapton Road, Barnham

Please upload the email below from the applicant to **BN/93/19/PL**.

Thanks,

Michael

Michael Eastham | Principal Planning Officer, Strategic Development, Directorate of Place, Arun District Council | Location: First Floor,
Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37772 | External: +44 (0) 1903 737772 | E-mail: Michael.eastham@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: 
Sent: 19 February 2020 18:36
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: BN/93/19/PL - Angels Nursery, Yapton Road, Barnham

Michael

Thank you for the email; and for the draft report (see note below).

I have been struggling with Southern Water's request; and I have been trying to rationalise their request in planning terms (and I'm still struggling).

Southern Water have asked for 24 months' notice to complete upgrades (if necessary) in the email below. I believe planning permission for 95 homes was granted on this site on 3rd May 2017 (33 months ago), so they have already had 9 months longer than requested to prepare for the works. Why do Southern Water actually need 57 months to upgrade the network? (I would also highlight that there is an implemented planning permission for 86 homes dating back to 14th March 2014 – so they've actually had 71 months, with the additional 24 months they're asking for they will have been working on the issue for 95 months).

Given Arun District Council have been identified in the recent Housing Delivery Test as an authority that must provide a 20% buffer to their housing land supply and prepare an action plan in relation to housing delivery; Redrow are surprised that there is a willingness to entertain conditions such as this that will delay delivery of homes, particularly on an allocated site with an implemented permission and an extant consent.

Unfortunately the proposed condition does not provide any certainty, there is no control mechanism, and it does leave Redrow potentially at the whim of Southern Water (what do Redrow do if Southern Water don't do any upgrade works, should the site be started, but no homes occupied?). We have no indication of what the phasing and implementation of any sewerage network reinforcements proposed by Southern Water (as set out above they've already had at least 33 months to prepare). In addition it would appear that any condition proposed by Southern Water will not meet the tests of a condition, as it appears to be requiring compliance with other regulatory requirements (in this case the Water Industry Act). The NPPG sets out that:

Are there any circumstances where planning conditions should not be used?

Any proposed condition that fails to meet one of the 6 tests should not be used. This applies even if the applicant suggests or agrees to it, or it is suggested by the members of a planning committee or a third party. Specific circumstances where conditions should not be used include:

Conditions requiring compliance with other regulatory requirements (eg Building Regulations, Environmental Protection Act);

Conditions requiring compliance with other regulatory regimes will not meet the test of necessity and may not be relevant to planning. Use of informatives to remind the applicant to obtain further planning approvals and other consents may be more appropriate.

Therefore, at best, Redrow would suggest an informative is added to the consent in line with the text requested by Southern Water.

In relation to the draft report, I note that the amendments to the conditions requested have been included (thank you), I note that the additional conditions requested by the Council have been included, but these have (generally) been extended beyond prior to commencement, which is also appreciated.


Therefore (with the exception of the Southern Water issue), Redrow are content for this matter to proceed.

Kind regards

Craige

Craige Burden
Head of Planning

Redrow Homes Limited
Redrow House Unit 1 Faraday Office Park
Rankine Road, Basingstoke
Hampshire, RG24 8QS



DEVELOPING THRIVING COMMUNITIES BY
VALUING PEOPLE AND BUILDING RESPONSIBLY

The contents of this email are subject to Redrow's disclaimer. Click [here](#) to read our disclaimer.

Think before you print

From: Michael Eastham <Michael.Eastham@arun.gov.uk>

Sent: 19 February 2020 10:32

To: [Redacted]

Subject: Fw: BN/93/19/PL - Angels Nursery, Tipton Road, Barnham

Importance: High

=====
THIS EMAIL ORIGINATED FROM AN EXTERNAL SOURCE.
CHECK THE EMAIL ADDRESS, AS IT MAY BE SPAM!
=====

Craige,

I have received the following email from Southern Water.

Are you happy with the condition highlighted by me in yellow below being inserted in the Decision Notice?

Kind regards,

Michael

Michael Eastham | Principal Planning Officer, Strategic Development, Directorate of Place, Arun District Council | Location: First Floor,
Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37772 | External: +44 (0) 1903 737772 | E-mail: Michael.eastham@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 19 February 2020 10:02
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: BN/93/19/PL - Angels Nursery, Yapton Road, Barnham

Hi Michael


There is a right to connect to our sewer under s106 and we cannot prevent this. What we ask is that from the date of planning permission being granted we are given 24 months to construct any network reinforcement should this be required and that the developer keeps in contact with us on progress, standard text from our response is as follows:

*Southern Water hence requests the following condition to be applied:
Occupation of the development is to be phased and implemented to align with the delivery by Southern Water of any sewerage network reinforcement required to ensure that adequate waste water network capacity is available to adequately drain the development.*

Regards

Joff

Joff Edevane
Growth Planning Lead



From
Southern Water

From: Michael Eastham [<mailto:Michael.Eastham@arun.gov.uk>]
Sent: 18 February 2020 15:49
To: [REDACTED]
Subject: BN/93/19/PL - Angels Nursery, Yapton Road, Barnham

Dear Joff,

The Local Planning Authority has imposed the following condition on a planning permission for residential development at Angels Nursery, on Yapton Road in Barnham.

“The development shall not commence until full details of the proposed foul water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. Including details of its routing, design, and subsequent management / maintenance.

No building shall be occupied until the foul water drainage scheme has been implemented in accordance with the approved details and the details so approved shall be retained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with Policy D DM1 and Policy W DM1 of the Arun Local Plan.”

Redrow Homes are claiming that the proposed Condition (Condition 28: Foul Water Drainage) is considered unnecessary. The Water Industry Act 1991 (as amended) controls the connection of homes / developments to the

foul water network. Redrow already has consent under the act to connect (via section 106 agreement) and the proposed sewers will be adopted (via section 104 of the act). As you will be aware conditions should not be used where they require compliance with other regulatory requirements, this condition is requiring compliance with the Water Industry Act and is therefore does not pass the tests for a condition. This is our most significant concern.

What is the view of Southern Water to the claim made by Redrow Homes?

I look forward to receiving your reply.

Regards,

Michael

Michael Eastham | Principal Planning Officer, Strategic Development, Directorate of Place, Arun District Council | Location: First Floor,
Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37772 | External: +44 (0) 1903 737772 | E-mail: Michael.eastham@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

Click [here](#) to report this email as spam.

This e-mail is intended solely for the person or organisation to which it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you are prohibited from copying, disclosing or distributing this e-mail or its contents (as it may be unlawful for you to do so) or taking any action in reliance on it. If you receive this e-mail by mistake, please delete it then advise the sender immediately. Without prejudice to the above prohibition on unauthorised copying and disclosure of this e-mail or its contents, it is your responsibility to ensure that any onward transmission, opening or use of this message and any attachments will not adversely affect

your or the onward recipients' systems or data. Please carry out such virus and other such checks as you consider appropriate. An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices. This e-mail is issued by Southern Water Services Limited, company number 2366670, registered in England and having its registered office at Southern House, Yeoman Road, Worthing, BN13 3NX, England. In sending this e-mail the sender cannot be deemed to have specified authority and the contents of the e-mail will have no contractual effect unless (in either case) it is otherwise agreed between Southern Water Services Limited and the recipient.

This message has been scanned for malware by Websense. www.websense.com

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
