




from
**Southern
Water**

June Grinstead
Your Home Plans Ltd
Chichester Enterprise Centre
Terminus Road
Chichester
West Sussex
PO19 8TX

Your ref
.....

Our ref
DS_CC_PDE-116162

Date
13 August 2020



Dear Ms Grinstead,

Level 1: Capacity check application for: Flamstead, Lake Lane, Bognor Regis, West Sussex, PO22 0AD.

Thank you for your capacity check application relating to the above site.

Please note, the revised documents submitted indicate that the proposed surface water flows are now restricted and hence will support the system to be more efficient. Therefore, surface water may be discharged to the existing sewer, provided the rate of discharge to the sewer is no greater than existing contributing flows.

Please ensure you quote our reference number as shown above.

Should you require any further advice please do not hesitate to contact our office on the above telephone number.

Yours sincerely,



Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366870