

[REDACTED]

[REDACTED]

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 27 October 2020 15:59
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: BN/97/20/PL- angels nursery

Drainage Engineers Comments on Surface Water Drainage

The drainage statement submitted does not support the layout plan. Please can the applicant identify if the proposals amount to a change in impermeable area over the previously approved drainage scheme. Please can they also supply details of how this revised layout will be drained. Until such a time as this information is submitted we wish to raise a holding objection.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk or [REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

