

[REDACTED]

From: John Carver [REDACTED]
Sent: 09 February 2021 12:03
To: Planning.Responses [REDACTED]
Subject: RE: Request for further information BN/9/21/DOC

FAO Nicola Moore

Dear Nicky

Further to your e-mail and our telephone conversation concerning additional information regarding the provision of a fire hydrant.

Following discussions with Ian Stocks from West Sussex Fire and Rescue it was agreed that the provision of a 45,000 ltr static water supply would be acceptable in lieu of a hydrant. In addition to this the applicant is proposing to install a fire suppressing sprinkler system in the building utilizing the static water supply for the purpose.

The attached plan shows the location of the proposed supply tank also attached is a copy of correspondence from WSFR regarding the volume of water required and connection details for WSFR hoses.

I hope this is helpful

Kind regards

Jon

[REDACTED]

