

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 16 June 2022 10:26

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Clock Walk High Street Bognor Regis PO21 1SG - BR/107/22/DOC

Planning Application Reference: BR/107/22/DOC

Proposal: Approval of details reserved by condition imposed under BR/199/19/PL relating to conditions 3-internal noise details and 6-bin storage

Location: Clock Walk High Street Bognor Regis PO21 1SG

Dear Maria,

Having reviewed the document entitled 'Environmental Noise Assessment | On Behalf of Carlton Park Construction Ltd | For the site at: Clock Walk, 7 High Street, Bognor Regis, PO21 1SG | Ref: AA/22/5/CC/CW/NIA' (dated 2nd May 2022) [produced by Amber Acoustics], I note the main identified noise source to be traffic. The recommended acoustic performance of the glazing must therefore include R_{tra} to effectively mitigate traffic noise.

I therefore request that the report be amended to include appropriate glazing acoustic performance recommendations.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

