

Maintenance Schedule for Extraction System

Carbon Units for PA240824

We will check the carbon filters every 3 months. The likelihood of replacement of Carbon Units are estimated every 12-14 months.

Fan Cleaning for Flaktwoods 56 JM

We are aware that the correctly maintained Extraction Fan has many benefits:



- Safe and comfortable temperature for work
- Safe noise level – appropriate level of communication
- Prolonged lifespan
- Reduced vulnerability –
(70% of kitchen fires start in the extraction canopies/ductwork)
- Eco Friendly business
- To comply with Insurance & Fire Regulations (see below)

We will clean the fan every 12 months.

Duct & Ventilation Cleaning

The need for duct cleaning will depend on the level of usage, types and quantity of food and other risk factors such as vulnerability of the system to ignite and the potential effect on building occupants. We anticipate the regular cleaning of the ducts every 12 month will be sufficient to improve airflow, eliminates odour and bacteria and obviously to reduce the risk of fire.

Canopy Cleaning

We will clean the canopy units once every week.