

From: Amanda Scholes on behalf of Planning.Responses
Sent: 30 January 2020 12:41
To: Planning Scanning
Subject: FW: Network Rail Consultation - BR/11/20/HH : 3 Highcroft Avenue

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Alghoul Dalia
Sent: 30 January 2020 12:14
To: Planning.Responses
Subject: Network Rail Consultation - BR/11/20/HH : 3 Highcroft Avenue

Dear Sir/Madam

Thank you for consulting Network Rail regarding the above planning application.

After careful consideration of the above planning application Network Rail has the following observations to make;

The developer **must** ensure that their proposal, both during construction and after completion of works on site, does not:

- Encroach onto Network Rail land
- Affect the safety, operation or integrity of the company's railway and its infrastructure
- Undermine its support zone
- Damage the company's infrastructure
- Place additional load on cuttings
- Adversely affect any railway land or structure
- Over-sail or encroach upon the air-space of any Network Rail land
- Cause to obstruct or interfere with any works or proposed works or Network Rail development both now and in the future

The developer should comply with the following comments and requirements for the safe operation of the railway and the protection of Network Rail's adjoining land.

Future maintenance

The development must ensure any future maintenance can be conducted solely on the applicant's land. The applicant must ensure that any construction and any subsequent maintenance can be carried out to any proposed buildings or structures without adversely affecting the safety of, or encroaching upon Network Rail's adjacent land and air-space, and therefore all/any building should be situated at least **2 metres (3m for overhead lines and third rail)** from Network Rail's boundary. The reason for the **2m (3m for overhead lines and third rail)** stand off requirement is to allow for construction and future maintenance of a building and without requirement for access to the operational railway environment which may not necessarily be granted or if granted subject to railway site safety requirements and special provisions with all associated railway costs charged to the applicant. Any less than **2m (3m for overhead lines and third rail)** and there is a strong possibility that the applicant (and any future resident) will need to utilise Network Rail land and air-space to facilitate works. The applicant / resident would need to receive approval for such works from the Network Rail Asset Protection Engineer, the applicant / resident would need to submit the request at least 20 weeks before any works were due to commence on site and they would be liable for all costs (e.g. all possession costs, all site safety costs, all asset protection presence costs). However, Network Rail is not required to grant permission for any third party access to its land. No structure/building should be built hard-against Network Rail's boundary as in this case there is an even higher probability of access to Network Rail land being required to undertake any construction / maintenance works. Equally any structure/building erected hard against the boundary with Network Rail will impact adversely upon our maintenance teams' ability to maintain our boundary fencing and boundary treatments.

Drainage

Storm/surface water must not be discharged onto Network Rail's property or into Network Rail's culverts or drains except by agreement with Network Rail. Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail's property. Proper provision must be made to accept and continue drainage discharging from Network Rail's property; full details to be submitted for approval to the Network Rail Asset Protection Engineer. Suitable foul drainage must be provided separate from Network Rail's existing drainage. Soakaways, as a means of storm/surface water disposal must not be constructed near/within 10 – 20 metres of Network Rail's boundary or at any point which could adversely affect the stability of Network Rail's property. After the completion and occupation of the development, any new or exacerbated problems attributable to the new development shall be investigated and remedied at the applicants' expense.

Plant & Materials

All operations, including the use of cranes or other mechanical plant working adjacent to Network Rail's property, must at all times be carried out in a "fail safe" manner such that in the event of mishandling, collapse or failure, no plant or materials are capable of falling within 3.0m of the boundary with Network Rail.

Scaffolding

Any scaffold which is to be constructed within 10 metres of the railway boundary fence must be erected in such a manner that at no time will any poles over-sail the railway and protective netting around such scaffold must be installed. The applicant/applicant's contractor must consider if they can undertake the works and associated scaffold/access for working at height within the footprint of their property boundary.

Piling

Where vibro-compaction/displacement piling plant is to be used in development, details of the use of such machinery and a method statement should be submitted for the approval of the Network Rail's Asset Protection Engineer prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement.

Fencing

In view of the nature of the development, it is essential that the developer provide (at their own expense) and thereafter maintain a substantial, trespass proof fence along the development side of the existing boundary fence, to a minimum height of 1.8 metres. The 1.8m fencing should be adjacent to the railway boundary and the developer/applicant should make provision for its future maintenance and renewal without encroachment upon Network Rail land. Network Rail's existing fencing / wall must not be removed or damaged and at no point either

during construction or after works are completed on site should the foundations of the fencing or wall or any embankment therein, be damaged, undermined or compromised in any way. Any vegetation on Network Rail land and within Network Rail's boundary must also not be disturbed. Any fencing installed by the applicant must not prevent Network Rail from maintaining its own fencing/boundary treatment.

Lighting

Any lighting associated with the development (including vehicle lights) must not interfere with the sighting of signalling apparatus and/or train drivers vision on approaching trains. The location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway. The developers should obtain Network Rail's Asset Protection Engineer's approval of their detailed proposals regarding lighting.

Noise and Vibration

The potential for any noise/ vibration impacts caused by the proximity between the proposed development and any existing railway must be assessed in the context of the National Planning Policy Framework which hold relevant national guidance information. The current level of usage may be subject to change at any time without notification including increased frequency of trains, night time train running and heavy freight trains.

Landscaping

Where trees/shrubs are to be planted adjacent to the railway boundary these shrubs should be positioned at a minimum distance greater than their predicted mature height from the boundary. Certain broad leaf deciduous species should not be planted adjacent to the railway boundary as the species will contribute to leaf fall which will have a detrimental effect on the safety and operation of the railway. We would wish to be involved in the approval of any landscaping scheme adjacent to the railway. Where landscaping is proposed as part of an application adjacent to the railway it will be necessary for details of the landscaping to be known and approved to ensure it does not impact upon the railway infrastructure. Any hedge planted adjacent to Network Rail's boundary fencing for screening purposes should be so placed that when fully grown it does not damage the fencing or provide a means of scaling it. No hedge should prevent Network Rail from maintaining its boundary fencing. Lists of trees that are permitted and those that are not permitted are provided below and these should be added to any tree planting conditions:

Permitted: Birch (Betula), Crab Apple (Malus Sylvestris), Field Maple (Acer Campestre), Bird Cherry (Prunus Padus), Wild Pear (Pyrus Communis), Fir Trees – Pines (Pinus), Hawthorne (Cretaeagus), Mountain Ash – Whitebeams (Sorbus), False Acacia (Robinia), Willow Shrubs (Shrubby Salix), Thuja Plicatata "Zebbrina"

Not Permitted: Alder (Alnus Glutinosa), Aspen – Popular (Populus), Beech (Fagus Sylvatica), Wild Cherry (Prunus Avium), Hornbeam (Carpinus Betulus), Small-leaved Lime (Tilia Cordata), Oak (Quercus), Willows (Salix Willow), Sycamore – Norway Maple (Acer), Horse Chestnut (Aesculus Hippocastanum), Sweet Chestnut (Castanea Sativa), London Plane (Platanus Hispanica).

Vehicle Incursion



Where a proposal calls for hard standing area / parking of vehicles area near the boundary with the operational railway, Network Rail would recommend the installation of a highways approved vehicle incursion barrier or high kerbs to prevent vehicles accidentally driving or rolling onto the railway or damaging lineside fencing.

Network Rail strongly recommends the developer contacts AssetProtectionLondonSouthEast@networkrail.co.uk prior to any works commencing on site, and also to agree an Asset Protection Agreement with us to enable approval of detailed works. More information can also be obtained from our website <https://www.networkrail.co.uk/running-the-railway/looking-after-the-railway/asset-protection-and-optimisation/>

Kind Regards,

Dalia Alghoul

Town Planning Technician | Property
Network Rail
1 Eversholt Street | London | NW1 2DN



From: [planning.responses](#) [redacted]
Sent: 15 January 2020 10:49
To: Town Planning SE [redacted]
Subject: Acknowledgement of Planning Application: BR/11/20/HH : 3 Highcroft Avenue

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.
This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.
Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN

