

To: Planning.Responses

Subject: FW: Planning Consultation on: BR/121/14/PL

The chimney height will be subject to approval under Section 15 of the Clean Air Act 1993. The proposed chimney height is in excess of the minimum of 20.2m specified by DEFRA on appeal against refusal to approve the previous chimney height of 7m. Consequently EH have no objection to proposal.

Graham Evans | Senior Environmental Health Officer, Pollution Team, Arun District Council | Location: Third Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37694 | External: +44 (0) 1903 737694 | E-mail: graham.evans@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Helen Mills

Sent: 12 June 2014 16:26

To: Pollution

Subject: FW: Planning Consultation on: BR/121/14/PL

204141

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]

Sent: 12 June 2014 15:34

To: EH Planning Consultations

Subject: Planning Consultation on: BR/121/14/PL

To: Environmental Health - Graham Evans/Sarah Meeten

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

**Town and Country Planning (Development Management Procedure) (England) Order
2010 (as amended)**

Planning Permission

APPLICATION

BR/121/14/PL

NO:

Registered: 28th May
2014

Site Address: The Regis School Westloats Lane Bognor Regis PO21 5LH

Grid Reference: 492144 99998

Description of Works: Erection of freestanding flue for biomass boiler

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 10-JUL-14.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:
www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Regards
Planning Officer

consultee_email
