

From: Robert Findlay
Sent: 04 June 2014 14:40
To: Planning.Responses
Subject: FW: C203794 - BR/124/14/PD

I cannot comment regarding the proposals for flat 1 as the plans are not clear for this development.

No objections to flat 2 other than means of escape from the bedrooms is via another room of significant risk, unless means of escape windows are provided to escape from the bedrooms in the event of a fire.

no grant of Planning or Building Regulations approval is inferred or implied".

Rob Findlay
HMO Officer
Private Sector Housing and Public Health Team
Environmental Health
Ext: 37686

Rob Findlay | HMO Officer, Private Sector Housing and Public Health Team, [Arun District Council](#) | Location: Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37686 | External: +44 (0) 1903 737686 | E-mail: robert.findlay@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Fiona Fitzgerald
Sent: 04 June 2014 10:50
To: Robert Findlay
Subject: C203794 - BR/124/14/PD

Hi,

I haven't been given the original e-mail for this, just the complaint number. Change of use from offices to dwellings. Can you reply with your comments?

Thanks

Fiona

Fiona Fitzgerald | Environmental Health Officer, Environmental Health Department, Arun District Council | Location: Third Floor, Arun
Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37674 | External: +44 (0) 1903 737674 | E-mail: Fiona.Fitzgerald@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.