

From: Simon Davis
Sent: 10 June 2019 15:35
To: Jeannine Rodriguez [REDACTED]
Subject: RE: Planning Consultation on BR/126/19/DOC

Dear Jeannine,

Ok. Please provide the information by the 17th of June. Otherwise I will have to refuse the application.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Jeannine Rodriguez [REDACTED]
Sent: 10 June 2019 09:31
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: Re: Planning Consultation on BR/126/19/DOC

Hi Simon,

May we please have one more week to submit the additional information? My husband is still under a time-sensitive project.

Kind regards,
Jeannine Rodriguez

On May 14, 2019, at 10:54 AM, Simon Davis <Simon.Davis@arun.gov.uk> wrote:

Dear Jeannine,

The application expiry date is the 2nd of July 2019 but we will need time at our end to consider the information that you provide. Therefore, could you ensure that we have the amendments by say the 10th June.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Jeannine Rodriguez [REDACTED]
Sent: 14 May 2019 09:52
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: Re: Planning Consultation on BR/126/19/DOC

Dear Simon,

Thank you so much for your quick reply. By when do you need the amendments? My husband is in the middle of a time-sensitive build project for a customer. Would appreciate as much time as you can give us.

Thank you and kind regards,
Jeannine

On May 14, 2019, at 9:49 AM, Simon Davis <Simon.Davis@arun.gov.uk> wrote:

Dear Jeannine,

Yes that is fine. There is still time to accept amendments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Jeannine Rodriguez [REDACTED]
Sent: 13 May 2019 18:09
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: Re: Planning Consultation on BR/126/19/DOC

Dear Mr Davis,

Thank you for this information.

I'm hoping we can provide this as additional information without having to submit another application?

Thank you,
Jeannine Rodriguez

On May 13, 2019, at 6:06 PM, Simon Davis
<Simon.Davis@arun.gov.uk> wrote:

Dear Mrs Rodriguez,

Please see below comments from our drainage engineer advising on what else you need to provide in order to secure the discharge of the drainage condition.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 13 May 2019 16:33
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on BR/126/19/DOC

Engineers Comments Regarding Condition 3- surface water drainage

1. Insufficient storm durations have been detailed within calculations. Storm durations between 5 minutes and 24 hours should be examined.
2. Please can the applicant confirm when infiltration testing was completed, and to what depth.
3. Construction detail drawings are required.
4. Layout drawings need to be provided to scale and detailing proposed soakaway dimensions including invert and cover levels.
5. Catchpits need to be shown on plan upstream of all connections to soakaways.

I would recommend that the applicant looks at our drainage checklist, available here <https://www.arun.gov.uk/drainagechecklist>, for further detail on our requirements.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)



From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]

Sent: 07 May 2019 17:06

To: Land Drainage

Subject: Planning Consultation on BR/126/19/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION **BR/126/19/DOC**
NO:

Registered: 07-MAY-19

Site Address: 65C Gravits Lane Bognor Regis PO21 5LN

Description of Works: Approval of matters reserved by condition imposed under BR/208/14/PL relating to condition 3-surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to the email by 21st May 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our web please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Thanking you in anticipation

Planning Case Officer

post_con_email

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
