

**ADC Planning Consultation
Response from the Historic Buildings Adviser**

Application Number	BR/127/14/DOC
Address	104d Highfield Road Bognor Regis
Description	Application for approval of condition 2 or previously approved Listed Building application BR/203/14/L - relating to new windows
Case Officer	Anita Gardner
Site Visit	

Comment

The information provided via photograph is unclear and therefore we are unable to comment clearly.

It was evident that double glazing was being applied for and if so, this should be a slim system (approx. 11mm).

The drawing of the windows did not appear to correlate with the photograph provided. The panes are shown horizontal and not vertical. It was also unclear if these were to scale.

Please note that the windows should be of traditional timber construction.

Ian Wightman
Historic Buildings Adviser

Please note: The observations and comments expressed on this sheet are the views of the consultee concerned and are in no way binding on either the Council or its senior officers when making a decision on the application. Applicants or their agents should contact the case officer before acting on these views.