

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 28 May 2021 15:49

To: Simon Davis <Simon.Davis@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 9-11 Abbeyfield Richmond Avenue Bognor Regis PO21 2YE - BR/132/21/DOC

Planning Application Reference: BR/132/21/DOC

Proposal: Approval of details reserved by condition imposed under ref BR/145/19/PL relating to Condition Nos 4 - proposed screen wall/fences including new boundary to 13-17, 9 - electric vehicle charging and 10 - decentralised, renewable & low carbon energy.

Address: 9-11 Abbeyfield Richmond Avenue Bognor Regis PO21 2YE

Dear Simon,

I have reviewed the documents entitled 'Electric Vehicle Podpoint Hardware Setup Options' and 'Electric Vehicle Podpoint Commercial White Paper'. The condition requires details of a scheme for the provision of electric vehicle charging points.

Further information is required to clarify which type of charging point shall be used (type 2 or type 3) and the proposed location/s of the charging points, and how many charging points are proposed. The scheme should include a plan detailing the location of the proposed electric vehicle charging points. I therefore do not recommend discharge of condition 9 attached to permission BR/145/19/PL at this time.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

