

Simon Davis

From: [REDACTED]
Sent: 16 June 2021 12:26
To: Simon Davis [REDACTED]
Cc: 'robbie nelson'
Subject: RE: BR/132/21/DOC 9-11 Abbeyfield

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Simon

There is an small edge space around the parking area and the chargers can fit within this area, not interfering with the 2.4 x 4.8m bays.

Kind regards

Leeza Aldis-Hobbs
Chartered Architect ARB RIBA SPAB
AMdesign Architects
[REDACTED]

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 16 June 2021 12:19
[REDACTED]
Subject: RE: BR/132/21/DOC 9-11 Abbeyfield

Hi Leeza,

Thanks for this. However, can you confirm that in this position, they don't interfere with the actual area of the spaces i.e. that the charger unit is not within the 2.4 by 4.8m area? I would have thought the charger needs to be physically between the spaces.

Simon.

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874
E: simon.davis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning
Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil



[REDACTED]
Sent: 16 June 2021 12:10
To: Simon Davis <Simon.Davis@arun.gov.uk>; [REDACTED]
Cc: 'robbie nelson' [REDACTED]
Subject: RE: BR/132/21/DOC 9-11 Abbeyfield

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Simon

Thank you.
Absolutely we can reposition the chargers, see attached plan.

Kind regards

Leeza Aldis-Hobbs
Chartered Architect ARB RIBA SPAB
AMdesign Architects
[REDACTED]

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 16 June 2021 11:57
[REDACTED]

Subject: RE: BR/132/21/DOC 9-11 Abbeyfield

Dear Leeza,

Highways have responded to say that: "Thanks, no objection would be raised however I would suggest that the scheme is modified as If they are twin pod chargers it would make sense to move them to between the first and second space so they could easily serve four spaces rather than require cables to be trailed across or around the top space."

Is this something you can agree to change?

Simon.

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874
E: simon.davis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF