

Amber Willard

From: Richard Stefanski
Sent: 09 July 2021 09:5
To: Amber Willard
Cc: Alex Baxter
Subject: RE: br/143/21/clp

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Dear Amber

I can confirm:

- Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse will be obscure-glazing and non-opening unless parts of the window which can be opened are more than 1.7 meters above internal finished floor level.
- The materials used in any exterior work will be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse.

Kind regards

Richard

Richard Stefanski

JJR Designs - Architectural Services

Suite 6a, Church House, 94 Felpham Road, Felpham, West Sussex, PO22 7PG

Tel: -

Registered in England - No. 5923941

VAT Registration - No. 990 2884 82

JJR Designs Ltd cannot be held responsible for any faults, errors or omissions arising from any failure in the integrity of the transmission or in the retrieval of the data attached to this message. It is the responsibility of the recipient to verify the interpreted data against a corresponding hard copy print at the earliest opportunity; the contents of this email are to be considered for information only. Whilst suitable precautions against virus transmittal are taken by JJR Designs Ltd, we cannot accept any responsibility for viruses or their consequences

From: Amber Willard <[REDACTED]>
Sent: Friday, July 9, 2021
To: Richard Stefanski <[REDACTED]>
Subject: br/143/21/clp

Dear Mr Stefanski

I am just writing up BR/143/21/CLP at 140 London Road.

Please can you confirm that the rooflights on the side elevation will be obscured glazed to comply with

(c) any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Please also confirm that the

(a) the materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

Thank you
Amber

Amber Willard
Planning Officer



T: [REDACTED]
E: [REDACTED]

Please note I am regularly out of the office Thursdays.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LE

www.arun.gov.uk



Sign up to our newsletter [here](#)

To register to receive notification of planning applications in your area please go to www.arun.gov.uk/planning

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
