



Atkins Limited
Anglo St James House
394 Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858588
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

Your Ref

BR/145/10/

Our Ref

S/AR/2010/145

Date

23/08/2010

Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Dear Sir

Creation of 2no. 3-bedroom dwelling houses and removal of rear single storey extension to existing property.

**Land adj. to 7, Nelson Road, Aldwick, Bognor Regis, West Sussex PO21 2RY.
BR/145/10/**

Thank you for your letter dated 22/07/2010.

Please find attached a plan of the sewer records showing the approximate position of a public surface water sewer crossing the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

It might be possible to divert the public sewer, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

Should the applicant wish to divert apparatus:

1. The 225 mm diameter sewer requires a clearance of 3 metres either side of the sewer to protect it from construction works and allow for future access for maintenance.
2. No development or new tree planting should be located within 3 metres either side of the centreline of the public sewer
3. No new soakaways should be located within 5m of a public sewer.
4. All other existing infrastructure should be protected during the course of construction works.

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items (1) – (4) above also apply.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to divert the public sewers, prior to the commencement of the development."

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. To initiate a sewer capacity check to identify the appropriate connection point for the development, please contact *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (tel 01962 858688)*, or www.southernwater.co.uk"

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Yours faithfully



Network Development
Atkins Ltd, for Southern Water



SOUTHERN WATER



The position of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accepts no responsibility in the case of inaccuracy. The actual positions should be determined on site.

Based upon Information Service Digital Data, with the permission of the Controller of HM Land Registry, Copyright Reserved Licence (S. 97) 2005/001.

O.S. REF: SZ9299SE

Scale: 1:1000

Screen Print

WARNING: This plan is a reproduction of a printed document.

WARNING: This plan is a reproduction of a printed document.



Printed By: Ponnany

Date: 16-8-2010

Southern Water MapGuide Browser

Requested By: