Southern Water

ATKINS

ARUN DISTRICT COUNCIL
PLANNING SERVICES
24 AUG 2010
RECEIVED

[redacted]

Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

BR/145/10/
Our Ref
S/AR/2010/145
Date
23/08/2010

Dear Sir

Creation of 2no. 3-bedroom dwelling houses and removal of rear single storey extension to existing property.
Land adj. to 7, Nelson Road, Aldwick, Bognor Regis, West Sussex PO21 2RY.
BR/145/10/

Thank you for your letter dated 22/07/2010.

Please find attached a plan of the sewer records showing the approximate position of a public surface water sewer crossing the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

It might be possible to divert the public sewer, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

Should the applicant wish to divert apparatus:

1. The 225 mm diameter sewer requires a clearance of 3 metres either side of the sewer to protect it from construction works and allow for future access for maintenance.
2. No development or new tree planting should be located within 3 metres either side of the centreline of the public sewer
3. No new soakaways should be located within 5m of a public sewer.
4. All other existing infrastructure should be protected during the course of construction works.

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items (1) – (4) above also apply.

Atkins Limited is a WS Atkins plc company
Registered office: Woodcote Grove, Ashley Road, Epsom, Surrey KT18 5BW, England. Registered in England number 00000

ARUN DISTRICT COUNCIL BR/145/10/

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to divert the public sewers, prior to the commencement of the development."

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. To initiate a sewer capacity check to identify the appropriate connection point for the development, please contact *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (tel 01962 858688), or www.southernwater.co.uk*"

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Yours faithfully

[redacted]

Atkins Ltd, for Southern Water

[redacted]

SOUTHERN WATER

The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility for the accuracy of measurements. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. 100019315.

O.S. REF: S2929SE | Scale: 1:1000

Screen Print

WARNING: Mains and services may not be shown in private property.
WARNING: Distances (DNs) should not be scaled from this drawing.

Printed By: Ponnany | Date: 16-8-2010

Southern Water MapGuide Browser

Requested By:

ARUN DISTRICT COUNCIL BR/145/10/