

**From:** Fiona Fitzgerald
**Sent:** 17 September 2014 11:49
**To:** Simon Davis
**Subject:** BR/167/14/PL

Dear Simon,

With regard to this application, and the issues discussed, I am still of the mind that we need acoustic information to be provided to allow assessment of whether disamenity is likely to be caused to the neighbouring unit from this use.

Please ask the applicant to provide an acoustic report which details the likely noise breakout from the proposed use on the adjacent premises. A BS4142 style report would be acceptable.

Regards

Fiona

Fiona Fitzgerald | Environmental Health Officer, Environmental Health Department, Arun District Council | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37674 | External: +44 (0) 1903 737674 | E-mail: Fiona.Fitzgerald@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk Save the environment - think before you print.