

Janice Chapman

From: Ian Wightman [REDACTED]
Sent: 22 February 2013 10:10
To: Anthony Perry
Cc: Janice Chapman; Martyn White
Subject: RE: Myrtle Cottage, Bognor Regis

Dear Mr Perry,

Thank you for your email. I can confirm that this window detail is acceptable for the extension.

I am afraid we cannot agree to double-glazing in the main listed building though.

If I can be of further assistance please let me know.

Kind regards,

Dr Ian Wightman

Historic Buildings Adviser -
Design & Implementation
Chichester District Council
[REDACTED]

From: Anthony Perry [REDACTED]
Behalf Of Anthony Perry
Sent: 21 February 2013 09:58
To: Ian Wightman
Subject: Myrtle Cottage, Bognor Regis

Dear Dr Wightman

I attach an alternative using 12mm double glazing (4mm plus 4mm Krypton gas plus 4mm low e glass) giving U value 1.9 W/m sq. k. Our Client had wished for a max. of 1.6 but will accept this.

I have based the 18 x 57 deep glazing bar on those I used recently (18 x 44) with single glazing for restoration work at Blackbrook House, Fareham. This is an ovolo section. Blackbrook House is circa. 1806.

It is difficult to decide on what would be an appropriate glazing bar section for these 21st century windows in a period setting?

Would you allow this 12mm glazing in the restoration of the **existing** cottage windows (albeit using 18 x 44 bars) where existing windows are beyond recovery or alien to the cottage, or do you insist on single glazing to the restored/copied windows?

Looking forward to hearing from you at your earliest convenience.

Regards,
Anthony Perry

LEGAL DISCLAIMER

Communications on or through Chichester District Councils computer systems may be monitored or recorded to secure effective system operation and for other lawful purposes.