

		Client:	CALSTAN M&E LTD				Page Number:	Date:		
		Project:	PRINCE OF WALES, BOGNOR REGIS				4 of 9	31st August 2022		
		Engineer:	Final Commissioning Results Grille Sheet				Job / Contract Number:			
		Graham Pollard								
		Description of System:	Supply & Extract Ventilation - MVHR 3							
		Location:	Ground Floor							
LOCATION INFORMATION		DESIGN			TEST				%	COMMENTS
Grille Ref	Location	Size (m ²) (Hood)	Volume (m ³ /sec)	Velocity (m/sec)	Factor	Recorded Velocity (m/sec)	Final Velocity (m/sec)	Final Volume (m ³ /sec)	%	
SGK1	Kitchen/Dining 1	0.0079	0.030	3.80	1.00	4.00	4.00	0.032	105%	
SD	Bedroom 1	0.0079	0.014	1.77	1.00	1.90	1.90	0.015	107%	
SD	Bedroom 2	0.0079	0.014	1.77	1.00	1.80	1.80	0.014	102%	
SD	Bedroom 3	0.0079	0.014	1.77	1.00	1.80	1.80	0.014	102%	
EGK1	Kitchen/Dining 1	0.0079	0.030	3.80	1.00	4.00	4.00	0.032	105%	
EG	Bedroom 1	0.0079	0.014	1.77	1.00	1.90	1.90	0.015	107%	
EG	Bedroom 2	0.0079	0.014	1.77	1.00	1.80	1.80	0.014	102%	
EG	Bedroom 3	0.0079	0.014	1.77	1.00	1.80	1.80	0.014	102%	
Comments:										
Commissioned By:		[Redacted]				For:	Date: 31st August 2022		Instrument Used:	
Witnessed By:						For:	Date:		Type:	Anemometer
									BSRIA Ref:	117425