

						Client:		CALSTAN M&E LTD			Page Number:		Date:			
						Project:		PRINCE OF WALES, BOGNOR REGIS					7 of 9		31st August 2022	
						Engineer:			Final Commissioning Results Grille Sheet					Job / Contract Number:		
						Description of System:			Supply & Extract Ventilation - MVHR 6							
						Location:			1st Floor - Studio 4							
LOCATION INFORMATION			DESIGN			TEST				%	COMMENTS					
Grille Ref	Location		Size (m ²) (Hood)	Volume (m ³ /sec)	Velocity (m/sec)	Factor	Recorded Velocity (m/sec)	Final Velocity (m/sec)	Final Volume (m ³ /sec)	%						
SD	Studio 4		0.0079	0.014	1.77	1.00	1.90	1.90	0.015	107%						
EG	Studio 4		0.0079	0.014	1.77	1.00	1.90	1.90	0.015	107%						
Comments:																
Commissioned By: [Redacted] For: Date: 31st August 2022 Instrument Used:																
Witnessed By: For: Date:												Type:	Anemometer			
												BSRIA Ref:	117425			