

Zoe Toppin

From: Maria Tomalova
Sent: 25 August 2020 13:45
To: Planning.Responses
Subject: FW: BR/188/20/DOC

Please upload the below to the above application; Environmental Health officer comments.

Thank you

[Maria Tomalova](#) | Senior Planning Officer, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37510 | External: +44 (0) 1903 737510 | E-mail: maria.tomalova@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 25 August 2020 12:33
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: BR/188/20/DOC

Dear Planning,

An 'Outdoor Socket with fused spur for EV Charging' is not sufficient as it can only be used occasionally for EV charging, and is not designed to withstand the necessary charging loads and should not be used long term. Environmental Health is not happy for the EV charging point condition to be discharged. The applicant needs to show that they will be installing specific EV home charging points.

Regards

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)