

From: Carreon, Aileen A [REDACTED]
Sent: 30 October 2018 15:19
To: Amber Willard
Cc: Dehkal, Redouane S.; Anne De Sausmarez; Brooks, Paul
Subject: RE: Bognor Regis Creative Digital Hub BR/193/18/L

Hello Amber,

Good afternoon and hope you are well.

Further to your email to Anne de Sausmarez we have considered new proposed solutions to overcome the sizing issue. We have reduced the larger louvers and split them in halves.

New schedule shall be as follow:

- Number of vents at the front elevation façade (south) will be 6No.louvers as indicated on the drawing attached above.
 - 2No. Toilet extract louver at 350x350mm each
 - MVHR 1 with 1No. intake at 540x720mm and 1No. discharge at 540x720mm
 - MVHR 2 (auditorium) with 2No. Intake at 600x400mm
- Number of vents at the east elevation façade will be 2No.louvers as indicated on the drawing attached above
 - MVHR 2 (auditorium) with 2No. discharge at 600x300mm

Note: All louvers are terracotta colour finish

I hope you find the above in order.

Should you have further queries please just contact us.

Many thanks.

Regards
Aileen

Aileen Carreon BSc, MSc, MRICS
Senior Building Surveyor / Asset Management, Buildings + Places, EMIA
[REDACTED]

From: Anne De Sausmarez [REDACTED]
Sent: 29 October 2018 08:25
To: Brooks, Paul; Carreon, Aileen A
Cc: amber.willard@arun.gov.uk
Subject: FW: Bognor Regis Creative Digital Hub BR/193/18/L
Importance: High

Hi Paul,

Please see the response from Martyn below in respect of the vents. Are you able to provide him with any reassurance?

Happy to discuss as needed

Amber Willard

From: Martyn White on behalf of Conservation Officer
Sent: 09 November 2018 14:05
To: Amber Willard
Subject: RE: Bognor Regis Creative Digital Hub BR/193/18/L

Amber,

I have had a look at the additional information, and conclude that they are now acceptable. The vents will need to closely reflect the colour of the bricks on the two elevations. All of the vents should be positioned as high as possible so as to limit their impact.

Kind Regards

Martyn

Ma



From: Amber Willard
Sent: 30 October 2018 15:37
To: Conservation Officer
Subject: FW: Bognor Regis Creative Digital Hub BR/193/18/L

Hi,

Information below is revised sizing for the vents for BR/193/18/L.

Please let me know if this is okay.

Thanks
Amber

As
As
In



Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.