[redacted]

From: Maria Tomalova
Sent: 14 August 2019 09:50
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: BR/194/19/PL

Please find below email from the consultee –suggestion of condition with regards to above application.
(to be upload to this application)

Maria Tomalova | Senior Planning Officer, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37510 | External: +44 (0) 1903 737510 | E-mail: maria.tomalova@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk Save the environment - think before you print.

From: Christopher Davis
Sent: 12 August 2019 15:59
To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: BR/194/19/PL

Hi Maria

As suggested when we discussed this case earlier today….

Noise Enclosure Around Specific Plant or Machinery	Before [any / specified plant and / or machinery] is used on the premises, it shall be enclosed with sound insulating material and mounted in a way which will minimise transmission of structure-borne sound in accordance with a scheme to be agreed with the Local Planning Authority. The noise mitigation scheme should be maintained and shall not be altered without the prior written approval of the Local Planning Authority. **Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031**

Hope this helps

Christopher Davis
Senior Environmental Health Officer
Environmental Health Department
(01903) 737695 (direct line)
Arun Civic Centre | Maltravers Road | Littlehampton | BN17 5LF
www.arun.gov.uk/eh

ARUN
DISTRICT COUNCIL