




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 08 October 2021 16:32

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Ravenna Richmond Avenue West Bognor Regis PO21 2YG - BR/201/21/PL

Planning Application Reference: BR/201/21/PL

Proposal: Erection of a new building comprising of 3 No apartments (2 No 2 bed units & 1 No 1 bed unit), including alterations to the fenestration of the existing building (resubmission following BR/176/20/PL). This site is in CIL Zone 4 (Zero Rated) as flats.

Address: Ravenna Richmond Avenue West Bognor Regis PO21 2YG

Dear Maria,

Environmental Health has no objection in principle to the above proposal, however the following matters must be considered.

Electric Vehicle Charging Points

Prior to first use of the proposed development, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved dwelling shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working, the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Construction

Full details of all measures to be taken to deal with the emission of dust, odours or vapours arising from the construction phase of the development shall be submitted to, and approved in writing by, the Local Planning Authority prior to the first use of the premises. Any equipment, plant or process provided or undertaken in pursuance of this condition shall be installed prior to the first use of the premises and shall be operated and retained in compliance with the approved scheme.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

External Lighting

No external lighting shall be installed until details have been submitted to and approved in writing by the Local Planning Authority prior to the commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type; mounting height; aiming angles and luminaire profiles). The approved scheme shall be installed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation.

Reason: To protect the appearance of the area / the environment and wildlife / local residents from light pollution

Advisory - Heating Systems

We encourage the highest practicable standards of building insulation and use of renewable forms of heating (such as ground and air source heat pumps) as opposed to natural gas boilers where possible. This action would contribute to the improvement of local air quality and reduce overall GHG emissions in the long term.

Thank you for your consultation,

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

