



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Stride Treglown Ltd
One Wessex Way
Colden Common
Winchester
SO21 1WG

Your Ref: BR/214/16/DOC

Please ask for:

Mr D Innes

11 October 2016

Dear Mr T Russell

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for approval of details reserved by condition imposed under BR/54/16/PL relating to
condition No. 7 (Construction management plan), 10 (Surface water drainage), 12 (Watercourse), 14
(External lighting scheme), 15 (Noise), 16 (Public sewers), 17 (Foul & surface water sewerage
disposal), 18 (Cars), 19 (Roof plant), 23 (Landscaping scheme), 24 (Tree retention & protection plan),
25 (Programme of archaeological work & scheme of investigation), 26 (schedule of materials) & 34
(Programme of ecological work)
University of Chichester Upper Bognor Road, Bognor Regis,

Notification regarding the above application:

Condition Number 10

Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The sewer diversion proposals should be agreed and approved by Southern Water under s185 of the Water Industry Act before condition 10 can be discharged.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to read 'KARL', with a long, sweeping horizontal flourish underneath.

Karl Roberts
Director Planning & Economic Regeneration