

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 18 August 2017 10:23
To: Planning Scanning
Subject: FW: University of Chichester Technology Park (Bognor Regis Campus) - Condition 26 - Flint
Attachments: flint-detail-approved.jpg; flint-panel-alternatives.jpg; flint-panel-approved.jpg

This is email from agent.

From: Michael Eastham
Sent: 17 August 2017 12:49
To: Planning.Responses
Subject: FW: University of Chichester Technology Park (Bognor Regis Campus) - Condition 26 - Flint

Please upload this email trail and attachments onto Ocella.

This is a consultation response approving Condition 26 (BR/214/16/DOC) - University of Chichester Technology Park (Bognor Regis Campus).

Thanks,

Michael

From: Tony Russell [REDACTED]
Sent: 17 August 2017 11:58
To: Michael Eastham
Cc: Martyn White; Angela Haywood; Ian Wightman
Subject: University of Chichester Technology Park (Bognor Regis Campus) - Condition 26 - Flint

Michael

I am pleased to confirm that Ian Wightman visited site this morning and approved the flintwork for the Stage 1 building. The approved option is shown on the attached image "flint-panel-approved". The right hand portion of the panel includes a horizontal struck trowel line between flint courses which will be included and is shown in more detail on the attached image "flint-detail-approved". The contractor will use this sample panel as a reference during the construction of the works.

For your information the two alternative panels are shown on the attached image "flint-panel-alternatives". These panels used the mortar mix recommended by the flint specialist however the colour was considered to be less sympathetic to the other external materials proposed for the project.

We look forward to receiving your approval to our DOC application relating to Condition 26 as the flint sample panel was the only outstanding matter relating to this condition.

Regards

Tony

Tony Russell BA(Hons) DipArch RIBA
Senior Associate Architect



One Wessex Way,
Colden Common, Winchester, SO21 1WG

stridetreglown.com

Stride Treglown Ltd may monitor email traffic data and also the content of email for the purposes of security.

Registered Office: Promenade House, The Promenade, Clifton Down, Bristol, BS8 3NE. Registered Number: 1748850