

From: Simon Davis
Sent: 05 November 2018 15:37
To: 'ACH Planning Limited'
Subject: RE: Planning Consultation on: BR/214/18/PL

Dear Adrian,

We will require the submission of a Flood Risk Assessment due to the nature of the site being part in Flood Zones 2 and 3.

Looking back, I see this was not raised for the previous application but I would suggest that the flood mapping has changed since then.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: ACH Planning Limited
Sent: 05 November 2018 14:18
To: Simon Davis
Subject: RE: Planning Consultation on: BR/214/18/PL

Dear Simon

First, I apologise for providing inaccurate surface water and drainage detail, it was not my intention to misrepresent the situation, but based upon the information available to us at the time.

In the circumstances, it seems infinitely sensible to me to endorse the pre-commencement condition as you have suggested.

Should you require any additional information, please do not hesitate to contact me.

Kind regards

Adrian



ADRIAN HOY
SENIOR ARCHITECTURAL PLANNING CONSULTANT
ACH PLANNING
12 Market Square, Windsor, Bucks, MK18 3AF

www.achplanning.co.uk

ACH PLANNING LIMITED

Registered Address: 3 Carrera House, Merlin Centre, Gatehouse Close, Aylesbury, Buckinghamshire HP19 8DP
VAT Registration Number 203 8732 24, Company Number 9563249

From: Simon Davis <Simon.Davis@arun.gov.uk>

Sent: 05 November 2018 11:49

To: ACH Planning Limited [REDACTED]

Subject: FW: Planning Consultation on: BR/214/18/PL

Dear Adrian,

Please see below consultation advice and note the comment about flood risk. I see from both our mapping and the EA online maps (<https://flood-map-for-planning.service.gov.uk/>) that parts of the site (not all) lie in Flood Zones 2 & 3.

Condition ENGD2B is a pre-commencement condition therefore we will need your agreement to its use:

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDs Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactory drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to ensure that the surface water disposal scheme is agreed before construction commences.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons

Sent: 05 November 2018 11:41

To: Planning.Responses

Cc: Simon Davis

Subject: RE: Planning Consultation on: BR/214/18/PL

Engineers Comments Regarding Flood Risk and Surface Water Drainage

The application form states that the proposed site is not located within flood zone 2 or 3. This is incorrect and therefore a flood risk assessment needs to be provided and the Environment Agency consulted.

It should also be noted that the site is at low risk from surface water flooding, and west street is at moderate to high risk of surface water flooding.

Please apply ENGD2B

Soakaways must be investigated for surface water disposal.

Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE 365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location.

Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes are also enclosed for information.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]

Sent: 23 October 2018 11:49

To: Land Drainage

Subject: Planning Consultation on: BR/214/18/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

APPLICATION BR/214/18/PL

NO:

Registered: 1st October
2018

Site Address: Former hotel tennis courts adj to The Royal Norfolk Hotel West
Street West Sussex PO21 2LH

Grid Reference: 493199 98842

Description of Works: Erection of four terraced residential dwellings, garden/cycle storage sheds & associated car parking, utilising the existing access - This application may affect the character & appearance of The Steyne, Bognor Conservation Area & will affect the setting of a Listed Building

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 22-NOV-18.

You can also monitor the progress of this application through the Council web site: www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Regards
Planning Officer

consultee_email

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail"

in this disclaimer includes any attachments.
