







From: Mick Mew [REDACTED]
Sent: 01 December 2021 11:51
To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Cc: Nick Geall [REDACTED]
Subject: RE: BR/218/21/PL

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Maria,

Thanks for letting me know I look forward to hearing from you once you have reached your decision.

Regards,

Mick Mew

From: Maria Tomalova <Maria.Tomalova@arun.gov.uk>

Sent: 01 December 2021 11:48

To: Mick Mew [REDACTED]

Subject: RE: BR/218/21/PL

Dear Mr Mew,

Thank you for a further information.

ADC Environmental Health has been re-consulted.

Kind regards

Maria

Maria Tomalova
Senior Planning Officer
Directorate of Place



T: 01903 737510

E: maria.tomalova@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

From: Mick Mew [REDACTED]

Sent: 29 November 2021 16:10

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Joanne Lewis <Joanne.Lewis@arun.gov.uk>

Cc: Nick Geall [REDACTED] Joanne Lewis <Joanne.Lewis@arun.gov.uk>

Subject: RE: BR/218/21/PL

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Maria,

Sorry for the delay in responding to this request it appears to have just been overlooked, my apologies, I can confirm the materials which will be applied within the new paint booth will be as follows: -

Indestructible Paints IP9183-R1 High Heat resistance sacrificial aluminium coating.

Thinners: - Water.

Indestructible Paints IP9184-R1 Ipseal High Heat Temperature Inorganic Seal.

Thinners: - Water.

Indestructible Paints 985 Series Rockhard stove enamel paint.

Thinners: - Indestructible Paints IP985 – Reducer.

We would estimate with the product knowledge gained a total usage in weight of 100kg in total across all products, the components we intend to paint are various components from industrial gas turbine engines and manufactured from Aluminum and nickel based alloys.

Should you require any further information feel free to contact me directly.

Thanks in advance,

Mick Mew
Engineering Manager
Component Process and Repair Limited



Confidentiality: This e-mail and any attachments are confidential and may be privileged. If you are not the intended recipient please notify the sender immediately and do not disclose the contents to another person or use it for any purpose or store or copy the information in any medium

Component Process & Repair Limited

Registered Office: Dickinson Place, South Bersted Business Park, Bognor Regis, West Sussex PO22 9QU England

From: Richard Hollands [REDACTED]
Sent: 18 October 2021 09:18
To: Mick Mew [REDACTED]
Cc: Nick Geall [REDACTED]
Subject: FW: BR/218/21/PL

Good morning Mick

Trust you are keeping well

Had this email late on Friday – please go through the attached email comments from the Environmental Health.

You did convey originally that the equipment did a lot of filtering etc before release into the atmosphere.

Obviously re paint products used, solvents etc all need to be quantified.

You would need to go through all your products used list with the equipment manufacturer.

Obviously you would be up to date with the area of permits that are or could be required

Noise wise, if working within a basic say 7.30 – 4.30pm plus Saturday 7.30am to latest 1pm you should meet their work hours but again that is your decision re the actual days / times worked.

Will advise Planning officer that you will be working through the queries and will get a response back asap within the 2 weeks

Will await your written reply of answers so that I can forward to Planning – probably best if done as a pdf attachment

Many thanks and please be free to contact us if you have any queries

Kind regards

Richard

Grove Design UK

From: Maria Tomalova [<mailto:Maria.Tomalova@arun.gov.uk>]

Sent: 15 October 2021 17:56

To: Richard Hollands [REDACTED]

Subject: BR/218/21/PL

Dear Mr Hollands,

Please see below Environmental Health comments:

I refer to the above application and request that further information is provided in order for Environmental Health to make a decision on whether or not to object to the application or request certain conditions.

- The use of paint spray booths may require a permit under the Environmental Permitting Regulations 2016 depending on the type and quantity of paints or products to be used. If a permit is required this may dictate the stack heights in order to allow for adequate dispersion. In order to ensure that the stack heights applied for will be suitable should a permit be required, more information should be provided on the type and quantity of paints that are proposed to be used in the spray booth and what materials and products they are being applied to. The applicant may wish to review the process guidance note relevant to their business for further information on permit requirements (most likely under the solvents section) and the relevant note should be referred to in the extra information submitted. Local Air Pollution Prevention and Control (LAPPC): process guidance notes - [GOV.UK \(www.gov.uk\)](https://www.gov.uk)
- If a permit is required it is advisable for the planning application and permit application to be considered at the same time to ensure that all requirements of both legislative regimes can be met and to avoid unnecessary expenses and delays.

Noise

It is possible that a full noise assessment may be required given the existence of residential properties on Ash Grove. An important factor in determining whether this is required is the proposed operating hours. The applicant should therefore provide information on the proposed operating hours of the spray booth. If it is to operate at night this has more potential for noise disturbance.

If you want address the above comments, please provide further information within 2 weeks from the date of this email.

Kind regards

Maria

Maria Tomalova
Senior Planning Officer
Directorate of Place



T: 01903 737510
E: maria.tomalova@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

This e-mail and any attachments are confidential. If you are not the intended recipient, please notify the sender immediately by replying to this e-mail, and then delete it without making any copies or using it in any other way. The unauthorised use, disclosure or copying of this email, or any information it contains or any attachments to it is prohibited. Email transmission cannot be guaranteed to be secure or error free or not to contain viruses. Component Process and Repair Limited shall therefore in no way be liable for the contents of this document or any attachments.

Component Process and Repair Limited, Registered Office, Unit 2 Dickinson Place, South Eastern Business Park, Bognor Regis, West Sussex, PO22 9OU. Registered in England under No. 02521221

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

This e-mail and any attachments are confidential. If you are not the intended recipient, please notify the sender immediately by replying to this e-mail, and then delete it without making any copies or using it in any other way. The unauthorised use, disclosure or copying of this email, or any information it contains or any attachments to it is prohibited. Email transmission cannot be guaranteed to be secure or error free or not to contain viruses. Component Process and Repair Limited shall therefore in no way be liable for the contents of this document or any attachments.

Component Process and Repair Limited, Registered Office, Unit 2 Dickinson Place, South Eastern Business Park, Bognor Regis, West Sussex, PO22 9OU. Registered in England under No. 02521221