

[REDACTED]

From: Clare Sutton (MHA) [REDACTED]
Sent: 21 January 2019 10:19
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Mark Coates [REDACTED]; Satnam Kaur [REDACTED]
Subject: RE: BR/222/18/PL - Land adjacent to Community Centre, Westloats Lane

Dear Simon
We agree to these conditions.
Regards
Clare

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 18 January 2019 16:46
To: Clare Sutton (MHA) [REDACTED]
Cc: Mark Coates [REDACTED]; Satnam Kaur [REDACTED]
Subject: BR/222/18/PL - Land adjacent to Community Centre, Westloats Lane

Dear Clare,

I have started the Committee report this afternoon and have drawn up my list of suggested conditions. I will need to agree the pre-commencement ones with you before the Committee agenda is finalised. Therefore can you advise whether you will agree to the following pre-commencement conditions (which have been requested by consultees):

1	Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity. Reason: To ensure that the proposed development is satisfactorily drained in accordance with policy W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition because it would not be possible to implement a surface water drainage scheme once development had commenced.
2	No development shall be commenced until such time as plans and details have been submitted to and approved in writing by the Local Planning Authority showing the site set up during construction. This shall include details

	for all temporary contractors' buildings, plant and stacks of materials, provision for the temporary parking of contractors vehicles and the loading and unloading of vehicles associated with the implementation of this development. Such provision once approved and implemented shall be retained throughout the period of construction. Reason: To avoid undue congestion of the site and consequent obstruction to access in accordance with policies D DM1 and T SP1 of the Arun Local Plan and the National Planning Policy Framework. This is required to be a pre-commencement condition because it is necessary to have the site set-up agreed prior to access by construction traffic.
3	Development shall not commence until full details of the proposed measures to be undertaken to divert the existing public sewers have been submitted and approved in writing by the local planning authority (in conjunction with Southern Water). None of the dwellings shall be occupied until the measures in respect of diverting the sewer have been completed in accordance with the agreed details. Reason: To ensure that the proposed development does not result in any damage to the existing foul sewer in accordance with policies W DM1 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because new development has the potential to cause damage to any sewer crossing the site.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
 Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
 Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
 Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.