

From: Amanda Scholes on behalf of Planning.Responses
Sent: 25 September 2018 08:29
To: Planning Scanning
Subject: FW: BR/225/18/PL

From: Fiona Fitzgerald
Sent: 24 September 2018 14:18
To: Planning.Responses
Cc: Paul Broggi; Caroline Gosford
Subject: BR/225/18/PL

Dear Planning,

Environmental Health have no objection in principle to this application. However given the close location of the residential flats at Mountbatten Court and the potential intensification of use of the area as a result of this application, Environmental Health would require the following conditions to be placed on any permission given:

1. A noise management scheme shall be submitted to and approved in writing by the Local Planning Authority, which specifies the provisions to be made for the control of noise sources emanating from the site. Thereafter, the use shall not commence until the approved scheme has been fully implemented.
2. All plant, machinery and equipment installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated so that the rating level of noise emitted does not exceed the background sound level, when measured according to British Standard BS4142: 2014 at any adjoining or nearby noise sensitive premises.

Regards

Fiona