

From: Amanda Scholes on behalf of Planning.Responses
Sent: 12 November 2020 08:43
To: Planning Scanning
Subject: FW: Planning Consultation on: BR/234/20/PL

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Nick Howard <Nick.Howard@arun.gov.uk>
Sent: 11 November 2020 12:01
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: BR/234/20/PL

Dear Sirs,

EH comments below for the above planning application with reference to the Arun District Council Environmental Health Planning Conditions;

Planning Conditions

CD01 – Construction/Demolition Management Plan

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:-

- a. An indicative programme for carrying out of the works;
- b. Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;

- c. Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
- d. Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e. The parking of vehicles of site operatives and visitors;
- f. Loading and unloading of plant and materials, including permitted times for deliveries;
- g. Storage of plant and materials used in constructing the development;
- h. The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i. The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j. Measures to control the emission of dust and dirt during construction;
- k. A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

CD02 - Hours of working on construction/demolition sites

No construction / demolition activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no 'noisy' work on Sunday or Bank Holidays

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Notes: the words in square brackets may be adjusted to reflect site specific constraints

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

AQ01 - Electric Vehicle Charging Points

Prior to occupation of any of the dwellings, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved dwellings shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

Reason: New petrol and diesel cars / vans will not be sold beyond 2040, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

AQ04 - Air Quality

As this is a major application, consideration must be given to air quality issues. As per the National Planning Policy Framework (NPPF) (updated February 2019) air quality should be considered at the design stage and incorporate appropriate and effective mitigation.

The applicant must follow the Air Quality & Emissions Mitigation Guidance for Sussex (2013), available at:

<http://www.sussex-air.net/Consultation/AirQualitydocument.pdf>

This countywide adopted guidance states that where a major sized development is proposed a number of checklists should be followed in order to determine the likely impact of the proposed development on air quality. The intention of the guidance is to identify any air quality impacts through an impact assessment and ensure the integration of appropriate mitigation into a scheme at the design stage, so the damage costs on health can be properly mitigated. The air quality impact assessment can follow the procedures contained within the Institute of Air Quality Management (IAQM) Guidance entitled: 'Land-Use Planning & Development Control: Planning For Air Quality' (January 2017), available at:

<http://www.iaqm.co.uk/text/guidance/air-quality-planning-guidance.pdf>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

L01 - Lighting

Details of the proposed lighting scheme for the development shall be provided and approved by the Local Planning Authority before installation.

Due to the relative proximity of existing residential premises there is the potential for the development to cause a loss of amenity as a result of light glare / creep / bleed.

Light intrusion into residential windows shall not exceed 10 Lux between 07:00 and 21:00 hours and 5 Lux between 21:00 and 07:00 hours, measured as Vertical Illuminance (EV) normal to glazing. The Sky Glow (Upward Light Ratio) shall not exceed 5.0%

Prior to the commencement of the development, details of the external lighting of the site shall be submitted to and approved in writing by the Local Planning Authority. These details shall include the predictions of both horizontal illuminance across the site and vertical illuminance affecting immediately adjacent receptors. The lighting installation shall comply with the recommendations of the Institution of Lighting Professionals (ILP) "Guidance Notes for the Reduction of Obtrusive Light" (GN01:2011)

[Prior to occupation, the predicted illuminance levels shall be tested by a competent person to ensure that the illuminance levels agreed in the scheme are achieved. Where these levels have not been met, a report shall demonstrate what measures have been taken to reduce the levels to those agreed within the application scheme].

[The approved installation shall be maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to a variation].

Reason: To protect the amenity of local residents in accordance with Policy QE DM2 of the Adopted Arun Local Plan 2011 – 2031

PCL 01 – Potentially Contaminated Land

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Informative

Use of an acoustic fence barrier around the boundary of the site to help mitigate noise nuisance for neighbouring properties from works on the site.

Kind Regards

Nick Howard
Senior Environmental Health Officer
Environmental Health

T: 01903 737685
E: nick.howard@arun.gov.uk



Arun District Council, Civic Centre, Malltravers Rd, Littlehampton, West Sussex,
BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 20 October 2020 09:34
To: EHPlanningConsultations <EHPlanningConsultations@arun.gov.uk>
Subject: Planning Consultation on: BR/234/20/PL

To: **Environmental Health - Planning consultation**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: BR/234/20/PL
Registered: 16th October 2020
Site Address: Aronel Cottage Nursing Home 5-11 Highfield Road Bognor Regis PO22 8BQ
Grid Reference: 493725 99887
Description of Works: Three storey side extension comprised of twenty nursing units linked to the existing nursing home building. This site is in CIL Zone 4 (Zero Rated) as other development.

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 19th November 2020 . You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications <https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Maria Tomalova

Planning Officer- Arun District Council

Telephone: 01903 737510

Email: maria.tomalova@arun.gov.uk

