




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 10 December 2021 12:44

To: Amy Myer <Amy.Myer@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 65-71 Upper Bognor Road Bognor Regis PO21 1HR - BR/252/21/PL

Planning Application Reference: BR/252/21/PL

Proposal: Alterations to four listed buildings, extension of a listed building to create an office and warden's accommodation, erection of new building consisting of 3 No. flats, offices and workshops; creation of new private gardens, separation of this part of the site from the wider University campus, creation of a shared landscaped courtyard, areas for parking, and storage for bins and cycles. This application affects the setting of listed buildings and affects the character & appearance of the Upper Bognor Road & Mead Lane Conservation Area. It is in CIL Zone 4 (Zero Rated) as flats & other development

Address: 65-71 Upper Bognor Road Bognor Regis PO21 1HR

Dear Amy,

Environmental Health has no objection in principle to this application, however the following matters must be considered:

Electric Vehicle Charging Points

Prior to occupation of any of the dwellings or first use of the commercial units, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved development shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

****** I note from 'proposed site plan 5557-012-D' that 4 EVCPs have been included. In accordance with recent government guidance, any new residential dwellings (or existing dwellings undergoing major

refurbishment) with dedicated parking must have 1 EVCP per dwelling. For new non-residential buildings (or existing buildings undergoing major refurbishment), every 1 in 5 parking spaces must include a EVCP.

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Unexpected contamination

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93ijm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Internal Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

External Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the external noise levels within the curtilage of residential units will conform to the 'Design criteria for external noise' upper guideline value of 55 dB $L_{Aeq,T}$ as specified within section 7.7.3.2 of BS 8233:2014.

Guidance on sound insulation and noise reduction for proposed developments shall be submitted to and approved in writing by the Local Planning Authority. The work specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Thank you for your consultation,

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

