

From: Martyn White
Sent: 30 November 2018 09:39
To: Planning.Responses
Cc: Simon Davis
Subject: BR/256/18/L

BR/256/18/L

The application is for Listed Building Consent for installation of secondary glazing to all existing windows & doors.

Secondary glazing when carefully designed and installed allows the original windows to be retained unaltered, whilst reducing air/heat leakage. The proposed secondary glazing system attaches directly on to the rear of the existing windows in accordance with advice from Historic England. As a result there is no loss of historic fabric and the installation is easily reversible. It is therefore considered that the proposal accords with both guidance and policy and is acceptable and can be supported.

Martyn White | Principal Conservation Officer, Planning Policy, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37717 | External: +44 (0) 1903 737717 | E-mail: Martyn.white@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.