




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 10 December 2021 17:18

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Regis Lodge 3 Gloucester Road Bognor Regis PO21 1NU - BR/259/21/PL

Planning Application Reference: BR/259/21/PL

Proposal: Proposed change of use from C1 Guest House to 9 Bed. HMO (Sui generis) including internal and minor external alterations.

Address: Regis Lodge 3 Gloucester Road Bognor Regis PO21 1NU

Dear Maria,

Environmental Health has no objection in principle to this application, however the following matters must be considered.

Electric Vehicle Charging Points

I note from the Design and Access Statement that the proposal has considered that residents shall not be dependent upon private cars due to the location and local amenities. If any parking is to be included with the development, I recommend the following condition is included.

Prior to occupation of any of the dwellings, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved development shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

****In accordance with recent government guidance, any new residential dwellings (or existing dwellings undergoing major refurbishment) with dedicated parking must have 1 EVCP per dwelling.**

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Internal Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93jjm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Yours Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

