

From: Louise Crane
Sent: 22 December 2017 11:11
To: Planning.Responses
Subject: FW: Planning Consultation on: BR/266/17/PL

Comments from Environmental Health and Private Sector Housing:

Environmental Health

- No comments

Private Sector Housing

Fire Safety

- Appropriate fire precaution facilities and equipment must be provided of such type, number and location as are considered necessary. Guidance on fire safety is contained in the LACORS guidance document – “Housing – Fire Safety, Guidance on fire safety precautions for certain types of existing housing”

Room Sizes

- Room sizes should meet the minimum standards for houses in multiple occupation if the flats are intended to be rented.

General

- Must meet the requirements of the Housing Act 2004 and be free of Category 1 and significant Category 2 Hazards;
- Must meet the requirements of the Arun District Council Houses in Multiple Occupation Standards (2016);

Regards

Louise

Louise Crane | Principal Environmental Health Officer, Private Sector Housing & Public Health, Arun District Council | Location: Third Floor,
Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37669 | External: +44 (0) 1903 737669 | E-mail: louise.crane@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Sam Humphries
Sent: 28 November 2017 09:50
To: Anna Appleton

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]

Sent: 28 November 2017 09:18

To: EH Planning Consultations

Subject: Planning Consultation on: BR/266/17/PL

To: **Environmental Health - Anna Appleton**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

APPLICATION **BR/266/17/PL**

NO:

Registered: 22nd November
2017

Site Address: First Floor & Second Floor Offices 2-8 Queensway Bognor
Regis PO21 1QT

Grid Reference: 493451 99031

Description of Works: Alteration to previously implemented scheme for 24 flats to
include a further 2 bedrooms & a further 2 bathrooms on a fifth
floor.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 28-DEC-17.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Richard Temple who can be contacted on telephone number 01903 737591.

Regards
Planning Officer

consultee_email
