

From: Amanda Scholes on behalf of Planning.Responses
Sent: 09 December 2020 09:33
To: Planning Scanning
Subject: FW: BR/270/20/DOC- 99 Victoria Drive Bognor Regis

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 08 December 2020 15:59
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Subject: BR/270/20/DOC- 99 Victoria Drive Bognor Regis

Engineers Comments Regarding Condition 5- Surface Water Drainage

- Please can the applicant update the permeable paving detail to be specific to the site, i.e. to show the minimum required depth.
- Please can it be confirmed/ detailed on the drawings what depth the perforated rings are to extend up to.
- We are unclear on why the ring soakaways extend to the depth they do when this depth does not appear to be required and the invert level will be down far below the peak recorded groundwater level. Please can the applicant provide some commentary on the design.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

