

From: Simon Davis

Sent: 24 January 2022 16:02

Subject: RE: Planning Consultation on: BR/274/21/DOC

Hi Michael,

Comments in response below:

The trees at 1.5m are really too small and at this size don't make the British Standard for Nursery Stock sizes, so therefore I would advise that these are specified as 6-8cm or 8-10 cm girth (approx. 2.0-2.5m) light standard trees (which is about the smallest size available within the tree category) – species choice is fine.

Shrubs are fine species and size wise, these would probably be a 5lt stock size

Hawthorne hedge (assumed bare root) 40-60 cm – these are fine, please can the quantity of these be confirmed.

Otherwise all ok

Please respond with the info by 31/01/22.

Best

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874
E: simon.davis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil
Sign up to our newsletter [here](#)

