

Application Correspondence

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 21 December 2017 17:16
To: Simon Davis
Subject: 36 Corbishley Rd

Hi Simon

Thanks for your email. The queries raised are answered below:

1. Provide silt trap manhole upstream of PCC ring soakaway.

We do not normally add silt trap manholes upstream of concrete ring soakaways as the soakaways themselves act as silt traps and can be cleaned out either manually or by tanker. The calculations do not include for soakage to occur through the base – only the sides for this reason.

2. Provide construction detail to show how permeable pavement construction interacts with PCC ring soakaway.

The concrete ring soakaway is not designed to interact with the permeable paving in this case as it can deal with the flow on its own without the assistance of the permeable paving.

3. Provide construction detail/calculations for the standalone section of permeable pavement.

The standalone permeable paving just needs to deal with rainfall that lands on it – it is not required to accept flow from other impermeable areas and as such, is an improvement on original soft landscaped areas.

Kind regards
Trish Paul