

From: Simon Davis
Sent: 21 December 2017 15:27
To: Planning.Responses
Subject: FW: 36 Corbishley Road BR/289/17/DOC

Further Drainage Comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Paul Cann
Sent: 21 December 2017 15:26
To: Simon Davis
Subject: RE: 36 Corbishley Road BR/289/17/DOC

Hi Simon

Think we are almost there. Just a few items to address;

1. Provide silt trap manhole upstream of PCC ring soakaway.
2. Provide construction detail to show how permeable pavement construction interacts with PCC ring soakaway.
3. Provide construction detail/calculations for the standalone section of permeable pavement.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 19 December 2017 17:19
To: Paul Cann
Subject: FW: 36 Corbishley Road BR/289/17/DOC

Hi Paul,

Received in response to your objection dated 22 November 17.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 15 December 2017 18:29
To: Simon Davis
Subject: Fwd: 36 Corbishley Road

Hi Simon

Please find below all the information required for discharge of condition 3.

Kind regards
Trish Paul

<1767-D1.1 Surface Water Drainage.pdf>