

-----Original Message-----

From: Simon Davis

Sent: 31 January 2018 12:47

To: Trish Paul [REDACTED]

Subject: RE: Corbishley Rd BR/289/17/DOC

Dear Trish,

I am writing up your decisions. However, I have the following issues:

(1) Condition 07 - Materials

To be acceptable, the materials need to match with the existing building. I am not currently convinced that the proposed roof tile will match with the existing. If you can provide an image of the proposed tile alongside the existing then this may convince me (or two images that can be easily compared). Also, you have stated that the bricks will be "Forterra LBC Sandtoft" however, I cannot find an image of these on the internet so I can't see what colour these are and so can't compare to the existing building.

(2) Condition 08 - Landscaping

Please provide further details of the proposed Cherry Tree and any other proposed plants i.e. Latin name, form & size at planting.

(3) Condition 12 - Cycle Storage Sheds

Please provide elevations or brochure images for the sheds you propose to implement.

One I have these details then I will be able to finish writing up the decisions.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: In the office next door to the Ash Room, first floor, Arun Civic Centre, Maltravers Road, Littlehampton,
BN17 5LF

