

Sloane and Brown Ltd
Unit 3B Woodhorn Business Centre
Woodhorn Lane
Oving
Chichester
PO20 2BX

Date: 12th November 2019

Please ask for: Andrew Wood

Tel: 01903 737768

Your Ref:

Our Ref: BR/291/19/DOC

Dear Mr Brown,

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Approval of details reserved by condition imposed under reference BR/225/18/PL relating to Condition
Nos 4 - noise management scheme and 5 - lighting management scheme.
Place St Maur Des Fosses Belmont Street Bognor Regis

Notification regarding the above application:

Condition Number 4

A noise management scheme shall be submitted to and approved in writing by the Local Planning Authority, which specifies the provisions to be made for the control of noise sources emanating from the site. Thereafter, the use shall not commence until the approved scheme has been fully implemented.

All plant, machinery and equipment installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated so that the rating level of noise emitted does not exceed the background sound level, when measured according to British Standard BS4142: 2014 at any adjoining or nearby noise sensitive premises.

Reason: To safeguard the amenities of neighbouring properties in accordance with Arun Local Plan policies D DM1 and QE DM1

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

This condition is discharged in so far as submission of details relates and refers to the following documents:

Noise Management Plan dated April 2019 received on 18/10/2019.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning