

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 14 March 2019 08:49
To: Planning Scanning
Subject: FW: BR/302/18/PL

From: Stuart Corbey
Sent: 13 March 2019 14:46
To: Planning.Responses
Subject: BR/302/18/PL

Please save as addition info from agent

From: Nick Hopper [REDACTED]
Sent: 04 March 2019 15:35
To: Stuart Corbey
Subject: DCLG Min Space standards - BR/302/18/PL

Hi Stuart

Thanks for your call earlier;
Just to recap we are working to DCLG min space standards for 1 bed 1 person requirement of 39 sqm or 37 sqm with a shower instead of a bath for both single bed units for Hawthorn rd proposal. We will make this explicit on the revised drawings to also include the parking, bin store and cycle store requirements you also mentioned,

Many thanks for your time,

Best wishes
Nick

--
Nick Hopper Dipl.Arch
ADS - Architectural Design Services
[REDACTED]