




From: Alan J Smith [REDACTED]
Sent: 05 February 2014 15:17
To: Simon Davis
Subject: RE: Application BR/318/13/ - Rear of 13 and 15 Richmond Avenue

Dear Mr Davies

Regarding the proposed biomass installation at Abbeyfield Care Home.

There are 2 flues from the cabin which emit no noticeable smoke output apart from a little during the initial ignition of the boilers (hence smoke control zone exception). only heat can be seen coming from them. Their location will be well away from any open windows which is usually the main concern.

Due to the construction of the cabins and modern boiler specification, no noise can be detected from pellet transfer or burning of the pellets and we have installed the same set up in a residential area in front of a hotel recently with no issues.

In response to the information required by the Environment Agency I can also supply the following:

All the necessary boiler emission details including noise and flue output data.

Boiler smoke exception certificate.

A pellet quality guarantee statement will can be provided from a suitable supplier in the area.

I will compile all the certificates and other information soon as possible, if you need further details please do not hesitate to contact me in due course.

Kind Regards

Alan Smith

Alan J Smith Bsc (Hons) ACIAT
Architectural Technologist



CONSTRUCTIVE
RENEWABLES LTD

From: Simon Davis [<mailto:Simon.Davis@arun.gov.uk>]

Sent: 05 February 2014 12:25

Subject: Application BR/318/13/ - Rear of 13 and 15 Richmond Avenue

Please find Environmental Health comments attached.

Kind Regards

Simon J Davis MRTPI, Senior Planning Officer, Development Control
Arun District Council (First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF)
Telephone: +44 (0)1903 737874
Visit Arun's web site at www.arun.gov.uk
P Save the environment - think before you print.