

Julie Grieves

From: Graham Evans
Sent: 17 February 2012 14:17
To: Planningecons
Subject: FW: Planning Consultation on: BR/37/12/
 No objection in principal from Environmental Health.

There is potential for noise from existing unspecified commercial uses at ground floor level to adversely impact upon the proposed dwellings. Details of the existing floor/ceiling partitions are not available should be required together with proposals for improving sound insulation.
 The floor/ceiling partition between proposed 1st and 2nd floor residential premises may be subject to Building Regulation sound insulation requirements. A suitable airborne sound insulation test may be necessary to confirm that the floor/ceiling partition at 1st & 2nd floor levels comply at least to Building Regulation standards for insulation between dwellings.

Graham Evans
 Senior Environmental Health Officer
 Arun District Council
 01903 737694

From: Helen Mills
Sent: 17 February 2012 12:07
To: Graham Evans
Subject: FW: Planning Consultation on: BR/37/12/

191351

Helen

From: planningecons@arun.gov.uk [mailto:planningecons@arun.gov.uk]
Sent: 16 February 2012 13:00
To: EH Planning Consultations
Subject: Planning Consultation on: BR/37/12/

To: **Environmental Health - John Green**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: BR/37/12/

Registered: 08-FEB-12
Site Address: First & Second Floors Queensway House Queensway Bognor Regis PO21 1QT

Grid Reference: 493445 99090

Category: Plan Applicat'n

Description of Works: Conversion of first and second floors of Queensway House to create 6 no. 2 bed dwellings and 10 no. 1 bed dwellings

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 15-MAR- 12.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Regards
Planning Case Officer

consultee_email
