



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Turner
Mordington Cottage
University of Chichester, Upper
BOGNOR REGIS
PO21 1HR

Your Ref:

Internet ref: PP-06730139

Please ask for:

Technical Support Unit on extn. 37711

12th February 2018

Dear Turner

Development:

Proposal 1, is in conjunction with ongoing routine upgrading of provisions, within the existing substation compound, excavate an area of ground 2m x 0.8m to then fill with 50mm MOT type 1 sub base material and once compacted, construct shutter board around the excavated area ready to then accept 100mm of Class C30 mass concrete with expansion joints where required. The GRP enclosure will then be situated on this base in the compound measuring: Height: 1.055m x Width: 0.81m x Depth: 0.35m which will not protrude over the existing fence line.

Proposal 2, is in conjunction with ongoing routine upgrading of provisions, within the existing substation compound, excavate an area of ground 6m x 3.5m to then fill with 50mm MOT type 1 sub base material and once compacted, construct shutter board around the excavated area ready to then accept 100mm of Class C30 mass concrete with expansion joints where required. This area is to be enclosed with a 2.4m high shiplap wooden fence for security purposes with a single gate to the eastern elevation to match/ mirror the existing substation compound. The height of the fence is to restrict from view the back-up generator proposed to be situated at that location which will stand 2.34m high. This is to make the area secure and reduce visibility to passers-by and deter any individuals who may look to gain unauthorised access to the compound.

Location:

University of Chichester Upper Bognor Road BOGNOR REGIS

Thank you for your application submitted via the internet on 8th February 2018. It is being dealt with by the Technical Support Unit and has been allocated the reference number **BR/41/18/PL**.

We will contact you shortly with further details.

This letter does not confirm validity of the application/documentation submitted.

Yours sincerely

Miss N Spencer
Technical Support Unit Officer

PMAC71p