

Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH



Lead Local Flood Authority

Amber Willard
Planning and Building Control
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Date 13 May 2026

Dear Amber,

RE: BR/53/26/PL - 57 Queensway, Bognor Regis, PO21 1QN

Thank you for your consultation on the above site, received on 27 April 2026. We have reviewed the application as submitted and wish to make the following comments.

The applicant has provided a Flood Risk Assessment and Drainage Statement to account for the local flood risk issues and surface water drainage at this location. Following a review of the submitted documents, the details are in accordance with NPPF and local planning policy W DM2 Flood risk & Policy W DM3 Sustainable Urban Drainage Systems in Arun Local Plan 2011-2031 (July 2018).

We have **no objection subject to conditions being attached to any consent** if this application is approved. We suggest the following wording. If the following conditions are not included, the development would be contrary to NPPF and local planning policy and we would **object** until such time that the details below are submitted for review.

Condition 1

Upon the commencement of development, construction drawings of the surface water drainage network, associated sustainable drainage components and flow control mechanisms and a construction method statement shall be submitted and agreed in writing by the Local Planning Authority. The scheme shall then be constructed as per the agreed drawings, method statement, FRA/Drainage Strategy (Urban Water, April 2026 and Drawing Proposed Drainage Layout Dwg. Dwg U0560-002-P1) and remaining in perpetuity for the lifetime of the development unless agreed in writing by the Local Planning Authority. No alteration to the agreed drainage scheme shall occur without prior written approval from the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with NPPF and Local Planning Policies W DM2 Flood risk & Policy W DM3 Sustainable Urban Drainage Systems in Arun Local Plan 2011-2031 (July 2018).

Condition 2

Upon completion of the surface water drainage system, including any SuDS features, and prior to the first occupation of the development; a survey and report from an independent surveyor shall be submitted to and approved in writing by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved pursuant to condition [1]. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the flood risk is adequately addressed, not increased and users remain safe for the lifetime of the development in accordance with NPPF and Local Policy
Yours sincerely

Mat Jackson
Flood Risk Management Team




Annex

The following documents have been reviewed, which have been submitted to support the application;

- Flood Risk Assessment, prepared by Urban Water, June 2025.
- Drainage Strategy Rev V2, prepared by Urban Water, December 2025
- Urban Water Response to ADC Engineers April 2026
- Dwg U0560-002-P1



PL- Consultation- WSCC Drainage response



Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Our priorities...




Improving the wellbeing of Arun



Delivering the right homes in the right places



Supporting our environment to support us



Fulfilling Arun's economic potential



Our core foundations



Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: [Redacted]
Sent: 13 May 2026 16:12
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Response To Application Number BR/53/26/PL at 57 QueenswayBognor RegisPO21 1QN

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Please could the attached response be distributed to the relevant case officer, Amber Willard

Regards

Mat Jackson

Please do not reply directly to this email.

Any formal reconsultation on the application should be directed to [Redacted] but the responding officer can be contacted directly via email if there are any questions relating to this response.

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.