




From: Nick Howard
Sent: 26 April 2018 14:21
To: Planning.Responses
Subject: RE: Planning Consultation on: BR/55/18/PL

Dear Andrew,

EH comments from the 'ARUN DC EH guide to commenting on planning applications' are as follows for the above application.

Noise Condition

Due to the location of the business -

16. All plant, machinery and equipment installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated so that the rating level of noise emitted does not exceed the background sound level, when measured according to British Standard BS4142: 2014 at any adjoining or nearby noise sensitive premises.

Kind Regards
Nick Howard
SEHO

From: Anna Appleton
Sent: 16 April 2018 13:55
To: Nick Howard
Subject: FW: Planning Consultation on: BR/55/18/PL

Hi Nick

Please can you respond.

Thanks

Anna

From: Sam Humphries
Sent: 11 April 2018 09:29
To: Anna Appleton
Cc: Sarah Meeten
Subject: FW: Planning Consultation on: BR/55/18/PL

Samantha Humphries | Information Management Assistant, Corporate Support
Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37393 | External: +44 (0) 1903 737500 | Fax: 01903 730442 |
E-mail: sam.humphries@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]

Sent: 11 April 2018 09:20

To: EH Planning Consultations

Subject: Planning Consultation on: BR/55/18/PL

To: **Environmental Health - Anna Appleton**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

APPLICATION **BR/55/18/PL**

NO:

Registered: 10th April
2018

Site Address: 2 Lennox Street Bognor Regis PO21 1LZ

Grid Reference: 493503 98956

Description of Works: Change of use from shop (A1 Shops) to (A3 Food & Drink/A4 Drinking Establishment. This application may affect the setting of a listed building & affects the character & appearance of The Steyne, Bognor Conservation Area.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 10-MAY-18.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if

any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Andrew Wood who can be contacted on telephone number 01903 737768.

Regards
Planning Officer

consultee_email
