

From: Laura Gibbons

Sent: 09 August 2019 12:29

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>

Subject: RE: Please find attached amendment on planning application Ref: BR/63/19/PL

Engineers Further Comments Regarding Surface Water Drainage

The revised site plan shows greater space is now available for surface water drainage. There is still very limited space available to the rear of plots 1, 2 and 6. Surface water drainage for each plot should be provided within that plots curtilage.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk <planning.responses@arun.gov.uk>

Sent: 25 July 2019 13:20

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Please find attached amendment on planning application Ref: BR/63/19/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: BR/63/19/PL

Registered: 25-MAR-19

Site Address: 15-17 Kew Gardens Bognor Regis PO21 5RD

Grid Reference:

Category: Plan Applicat'n

Description of Works: Demolition of existing building and erection of 6No. dwellings, 2x 3 bedroom and 4x 2 bedroom with associated access and car parking.

I am able to inform you that I have received an amendment to the above application dated 5th July 2019 relating to:- Amended plans and changed description

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'comment on this application'. Please make any further comment by 30th August 2019.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

[Click here to make further comments](#)

The officer dealing with this application is Ms M Tomalova who can be contacted on telephone number Senior Planning Officer.

Thanking you in anticipation

Planning Case Officer

pmac21_email
