



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 07 April 2022 11:17

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 99 Victoria Drive Bognor Regis PO21 2DZ - BR/67/22/DOC

Planning Application Reference: BR/67/22/DOC

Proposal: Approval of details reserved by condition imposed under BR/281/18/PL relating to conditions 3-site meeting with ADC tree officer & Arboricultural Expert, 7-landscape details & 9-details of new screen walls and/or fences.

Location: 99 Victoria Drive Bognor Regis PO21 2DZ

Dear Maria,

Having reviewed the document entitled 'Noise Impact Assessment | Proposed New Car Parking Area for a Proposed Residential Premises | Reference: HA/AE71/V1' (dated 11 March 2022) [produced by Health Abode Acoustics Ltd.] I find the report, methodology and findings to be reliable. I therefore recommend discharge of the condition providing the applicant installs an acoustic fence with a sound reduction value of 28dB_{Rw}, in accordance with the 'Healthy Abode Acoustics' report.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

